

This form has been designed to be used by licensed electrical workers to certify that installation or part installations under Part 1 or Part 2 of the AS/NZS 3000 are safe to be connected to the specified system of electrical supply.

Reference Holland-162562

Client Name Sarah Holland

Client Address 875 Gordonton Road, Waikato, 3281, Gordonton

Site Address 875 Gordonton Road, Waikato, 3281, Gordonton

Electrician Name hemal Kumar

Electrician Registration E273375

Company HK Electrical Ltd

Phone 0226288280

Email hkelectrical1@hotmail.com

Electrical Workers Ryan Neil EW155181

## Description of Work

Work Type Alterations

Prescribed Electrical Work General

Work Date 01 December 2022

Supply Type MEN240V

Reference Standards Part 2 of ASNZ3000

**Work Description** Reno home. Install new LED oyster lighting throughout, junction and extend cabling as needed for lights, relocate lounge light switch. Replace powerpoints throughout to new, remove surface installed powerpoints and re-run cabling in wall cavity. Fix rat damaged cables and junction/extend as needed. Make safe hot water circuit and install new exterior powerpoint for infinity. Install new smartvent in ceiling space and install new power supply from existing circuit. Install power for rangehood, junction in ceiling space. Install new cabling and power for oven with new oven kit. Install new inline fan in bathroom, rewire wiring as needed and junction in ceiling space. Install security lights outside. Install new heatpump in lounge area, wire in power feed back to switchboard on new 20a MCB. Install new powerpoint for dishwasher. Test and commission RCD test :pass Mega test :pass Earth continuity :pass

## Combined Electrical Certificate of Compliance and Electrical Safety Certificate Declaration

I certify that the completed prescribed electrical work to which this Certificate of Compliance applies has been done lawfully and safely, and the information in the certificate is correct in that the installation, or part of the installation and I certify that the installation, or part of the installation, to which this combined Electrical Safety Certificate applies is connected to a power supply and is safe to use.



**Relies on a supplier Declaration of Conformity**



**Relies on manufacturers instructions**



**Installed in accordance with certified design**



**Electronic / Other Reference**



**Has an earthing system that is correctly rated (where applicable)**



**Contains fittings that are safe to connect to a power supply**



**Has been satisfactorily tested in accordance with the Electricity (Safety) Regulation 2010**



**Is safe to connect**



**Certifiers Signature**

**02 December 2022**

**Date of Certification**

**01 December 2022**

**ESC Connection Date**

\*Attach or reference. If it is impractical to attach a copy of a particular manufacturer's instructions, or of any certified design or supplier declaration of conformity, provide a reference to where the documents can be found in a readily accessible format by electronic means.



This electrical safety certificate also confirms that the electrical work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.  
**This is an important document and should be retained for a minimum of 7 years.**